



# TOWN OF OXFORD

## Board of Health

325 Main Street, Oxford, MA 01540  
Phone (508) 987-6045 ext. 4  
Fax (508) 987-3934  
[boh@oxfordma.us](mailto:boh@oxfordma.us)

### **PERMIT EXPIRATION AND EXTENSION DATES**

<u>Permit Type</u>	<u>Expiration Date</u>
Donation Bins	December 31
Funeral Homes	April 30
Food Permit	June 30
Water-Pool-Beaches	October 31
Body Art Practitioners <b>2 YEAR RENEWAL</b>	December 31
Body Art Establishments <b>ANNUAL</b>	December 31
Bodywork Establishments <b>ANNUAL</b>	December 31
Tobacco	December 31
Haulers (Rubbish/Septic)	December 31
Installers	December 31
Trailer Parks-Camps	December 31

### **PERMIT EXTENSIONS, EXPIRATIONS, AND DISTANCE INFORMATION**

**Septic Repair/New Permit Extensions:** Once the plans are approved, they are good for three (3) years. Title 5 regulations state that the plans are good for three (3) years, but if someone would like an extension of one (1) year they need to fill out the extension form before the three (3) year extension date is up. **Fee: \$75.00 Only one (1) extension will be granted**

**Perc Test Results Extensions:** Soils/percolation testing results are valid from two (2) years of date of testing. Approval of the Request for Extension will extend the results two (2) years from time of original testing or from latest extension request. The applicant may extend soils/percolation tests as many times as desired as long as there are no changes in the State or Local regulations which would require changes in the soils testing procedure. **Fee: \$75.00 per every two (2) year extension requested**

**Well Permits Expiration, Extension and Distance:** Permit expires one (1) year from the date of issuance unless revoked for cause. Permits may be extended for one (1) additional six (6) month period provided that a written request is received by the BOH prior to the one (1) year extension date. A ten (\$10) dollar fee shall be charged for a permit extension, provided there is no change in the plans for the proposed well.

**Minimum separation distances allowed in construction of a well:**

<b><u>Component</u></b>	<b><u>Feet</u></b>
Septic System	
Leaching Facility	100
Septic Tank	50
Cesspool	100
Sewer Line	50
Driveway	15
Street	25
Buildings	20
Property Lines	10
Easements of Right-of-Way	10
Pond or Watercourse	
Drilled Well	25
Dug Well	100

**Title 5 Inspections:** Good for two (2) years, however, the inspection will be good for three (3) years if the customer can show documentation that the system was pumped/serviced each year on or before the anniversary date of your septic system inspection.

**Any Accessory Structure (# of feet away from):**

<b><u>Component</u></b>	<b><u>Feet</u></b>
Septic	10
Leach field	20
From Shed & House per Bldg. Code	4
Well	20